

CERTIFICATE OF CONFORMITY

This Certificate is issued to

OLS MANUFACTURING PTE LTD
3-B Joo Koon Circle
Singapore 629034

For Product Certification Scheme: Type 1b

Product : **Fire Damper**
Brand : **OLS**
Model : **RC-400V**
Country of Origin : **Singapore**
Product Details : **Galvanised steel or stainless steel uninsulated curtain type vertical fire damper for masonry wall and drywall partition**
Integrity: 240 mins;
Refer to Appendix for details.

which has complied with the requirements of the scheme based on the following:

STANDARD(S)	TEST REPORT(S)
SS 333: 2012, Annex E, Clause 6.3	TUV SUD PSB Test Report No.: 7191161709-MEC17-LJH
SS 333: 2012, Clause 6.5	TUV SUD PSB Assessment Report No.: 7191205740-MEC19-JC
ANSI/AMCA 500-D-07 (Air Leakage)	SETSCO Test Report No.: SK-8500013426/CCH/1
	AMCA Test Report No.: AA00128



Sze Thiam Siong (Mr)
Chief Executive Officer
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925


Certificate No	Date of Issue	Date of Last Revision	Date of Expiry
FSP-2019-0788	23/05/2017	04/03/2019	22/05/2022



This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is governed by SETSCO's Terms and Conditions for Certification. The certified client is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking SETSCO website at www.setsco.com

Type of Wall	Drywall partition (any types) with grille
Damper Overall Size (mm)	Single Module: 1500mm (W) x 1500mm (H)
	2 x 2 Module: 3000mm (W) x 3000mm (H)
	3 x 1 Module: 4500mm (W) x 1500mm (H)
	4 x 1 Module: 6000mm (W) x 1500mm (H)

Type of Wall	Masonry wall for thickness up to 2076mm and with grille
Damper Overall Size (mm)	Single Module: 1500mm (W) x 1500mm (H)
	2 x 2 Module: 3000mm (W) x 3000mm (H)
	3 x 3 Module: 4500mm (W) x 4500mm (H)



Sze Thiam Siong (Mr)
 Chief Executive Officer
 SETSCO Services Pte Ltd
 18 Teban Gardens Crescent
 Singapore 608925

Certificate No	Date of Issue	Date of Last Revision	Date of Expiry
FSP-2019-0788	23/05/2017	04/03/2019	22/05/2022

Amendments or additions to this appendix other than those authorized by SETSCO render the appendix invalid.

CERTIFICATE OF CONFORMITY

This Certificate is issued to

OLS MANUFACTURING PTE LTD
3-B Joo Koon Circle
Singapore 629034

For Product Certification Scheme: Type 1b

Product : Fire Damper
Brand : OLS
Model : RC-400H
Country of Origin : Singapore
Product Details : Galvanised steel or stainless steel curtain type floor mounted fire damper with grille and floor thickness up to 2076mm. Damper Overall Size:
Single Module: 1200mm (W) x 1686mm (H)
2 x 2 Module: 2400mm (W) x 3373mm (H)
Integrity: 240 mins

which has complied with the requirements of the scheme based on the following:

STANDARD(S)

SS 333: 2012, Annex E,
Clause 6.3
SS 333: 2012, Clause 6.5
SS 333: 2015, Clause 6.6
ANSI/AMCA 500-D-07 (Air
Leakage)

TEST REPORT(S)

TUV SUD PSB Test Report No.: 7191158303-MEC17-IHN
TUV SUD PSB Assessment Report No.: 7191203739-MEC19-JC
SETSCO Test Report No.: SK-8500013426/CCH/2
SETSCO Test Report No.: SK-85000/3426/CCH/1
AMCA Test Report No.: AA00128


Sze Thiam Siong (Mr)
Chief Executive Officer
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No

FSP-2019-0789

Date of Issue

23/05/2017

Date of Last Revision

04/03/2019

Date of Expiry

22/05/2022



This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is governed by SETSCO's Terms and Conditions for Certification. The certified client is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking SETSCO website at www.setsco.com