

CERTIFICATE OF CONFORMITY

This Certificate is issued to
OLS MANUFACTURING PTE LTD
(UEN No.: 197300608W)
3B Joo Koon Circle, Singapore 629034

For Product Certification Scheme: Type 1b

Product : Fire Damper

Brand : OLS

Model :	Model	Description
	RC-400V	Vertical fire damper for masonry wall
	RC-400D	Vertical fire damper for drywall
	RC-400H	Horizontal fire damper

Country of Origin : Singapore

Product Details : Galvanised steel or stainless steel uninsulated curtain type fire damper for masonry wall, drywall partition or floor masonry.
Integrity: 240 mins
Refer to Appendix for details.

which has complied with the requirements of the scheme based on the following:

STANDARD(S)

SS 333: 2012, Annex E, Clause 6.3
 SS 333: 2012, Clause 6.5
 SS 333: 2012, Clause 6.6
 SS 333: 2012, Clause 6.4

TEST REPORT(S)

TUV SUD PSB Test Report No.: 7191161709-MEC17-LJH
 TUV SUD PSB Assessment Report No.: 7191205740-MEC19-JC
 WARRINGTONFIRE WFA Report No.: 3004973-00
 SETSCO Test Report No.: SK-8500013426/CCH/1
 SETSCO Test Report No.: SK-8500013426/CCH/2
 SETSCO Test Report No.: MM-8500059071/CY

Detailed configuration and installation shall be referenced to the certified report(s) stated above.



Dixon Ng (Mr)
 Program Manager
 SETSCO Services Pte Ltd
 531 Bukit Batok Street 23
 Singapore 659547

Certificate No

FSP-2019-0788

Date of Issue

20/05/2022

Date of Expiry

22/05/2027

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.

Type of Wall	Drywall partition (any types) and with grille
Damper Overall Size (mm)	Single Module: 1500mm (W) x 1500mm (H)
	2 x 2 Module: 3000mm (W) x 3000mm (H)
	3 x 1 Module: 4500mm (W) x 1500mm (H)
	4 x 1 Module: 6000mm (W) x 1500mm (H)

Type of Wall	Masonry wall for thickness up to 2076mm and with grille
Damper Overall Size (mm)	Single Module: 1500mm (W) x 1500mm (H)
	2 x 2 Module: 3000mm (W) x 3000mm (H)
	3 x 3 Module: 4500mm (W) x 4500mm (H)

Damper Overall Size for floor application (mm)	Single Module : 1200mm (W) x 1686mm (H)
	2 x 2 Module: 2400mm (W) x 3373mm (H)



Dixon Ng (Mr)
Program Manager
SETSCO Services Pte Ltd
531 Bukit Batok Street 23
Singapore 659547

Certificate No
FSP-2019-0788

Date of Issue
20/05/2022

Date of Expiry
22/05/2027

Amendments or additions to this appendix other than those authorized by SETSCO render the appendix invalid.