



UNIT SIZE	INLET SIZES		WIDTH W	HEIGHT H	LENGTH		
	D				A	B	L
4	3 7/8 (98)		12 (305)	8 (203)	6 3/8 (162)	3 13/16 (97)	15 3/4 (400)
5	4 7/8 (124)						
6	5 7/8 (149)						
7	6 7/8 (175)						
8	7 7/8 (200)		14 (356)	10 (254)	4 3/8 (111)	5 5/16 (135)	19 1/4 (489)
9	8 7/8 (225)						
10	9 7/8 (251)						
12	11 7/8 (302)		16 (406)	15 (381)			
14	13 7/8 (352)		20 (508)	17 1/2 (445)	3 1/2 (89)	2 3/4 (70)	15 1/2 (394)
16	15 7/8 (403)		24 (610)	18 (457)			
24 x 16	23 7/8 (603) x 15 7/8 (403)		38 (965)				

STANDARD CONSTRUCTION:

- 1/2" (13mm) THICK INTERNAL FIBERGLASS INSULATION WHICH MEETS REQUIREMENTS OF NFPA 90A AND UL181.
- 22 GAUGE GALVANIZED STEEL HOUSING. MECHANICALLY SEALED, LEAK RESISTANT CONSTRUCTION.
- RECTANGULAR DISCHARGE OPENING WITH SLIP AND DRIVE CLEAT DUCT CONNECTION.
- MULTI-POINT, CENTER AVERAGING AIRFLOW SENSOR.
- 1/2" (13mm) GALVANIZED DAMPER SHAFT WITH POSITION INDICATOR.
- LEFT HAND UNIT SHOWN (CLH), RIGHT HAND AVAILABLE.

CONTROLS OPTIONS:

- FIELD MOUNTED CONTROLS, SUPPLIED BY OTHERS (FLD)
- FACTORY MOUNTED DIGITAL CONTROLS, SUPPLIED BY OTHERS (FAC)

CONTROLS SUPPLIED AND MOUNTED BY PRICE (EHP):

- DIGITAL CONTROLS (DIG)
- PNEUMATIC CONTROLS (PNEU)

UNIT OPTIONS:

- NEMA1 CONTROLS ENCLOSURE (PS)
- DISCONNECT SWITCH (DSW)
- 20 GAUGE CASING (20GA)
- HANGER BRACKETS (HB)
- BOTTOM REMOVABLE SENSOR (RS)
- BRASS AIRFLOW SENSOR GAUGE TAPS (GT)

BOTTOM ACCESS DOOR:

- ACCESS DOOR WITH SCREWS (AD)
- ACCESS DOOR WITH SNAP LATCHES (ADL)
- ACCESS DOOR WITH QUARTER TURN LATCHES (ADQ)

LINER OPTIONS:

- FIBERGLASS 1" (25mm) (FG1)
- FIBER FREE FOAM 1/2" (13mm) (FF50)
- FIBER FREE FOAM 3/4" (19mm) (FF75)
- FIBER FREE FOAM 1" (25mm) (FF1)
- FOIL FACED FIBERGLASS BOARD 1" (25mm) (FB1)
- SOLID METAL WITH FG1 (SM1)
- CLEANROOM ANGLES WITH FB1 (CRAF1)
- PERFORATED METAL WITH FB1 (AFPM1)



ALL METRIC DIMENSIONS () ARE SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO METRIC AND ROUNDED TO THE NEAREST MILLIMETER.

PROJECT:		PRICE
ENGINEER:		
CUSTOMER:		G
SUBMITTAL DATE:		269693
SPEC. SYMBOL:		SDV
		SINGLE DUCT TERMINAL VARIABLE VOLUME
		04/05/2021