

CERTIFICATE OF CONFORMITY

This Certificate is issued to
OLS MANUFACTURING PTE LTD
(UEN No.: 197300608W)
3B Joo Koon Circle, Singapore 629034

For Product Certification Scheme: Type 1b

Product : Fire Damper

Brand : OLS

Model :

Model	Description
RC-400V	Vertical fire damper masonry wall
RC-400D	Vertical fire damper for drywall or prefab drywall insulated panel

Country of Origin : Singapore

Product Details : Galvanised steel or stainless steel uninsulated curtain type fire damper for masonry wall, drywall partition or prefab drywall insulated panel.

Integrity	Type
120 mins	prefab drywall insulated panel
240 mins	masonry wall and drywall partition

Refer to Appendix for details.

which has complied with the requirements of the scheme based on the following:

STANDARD(S)

SS 333: 2022, Annex E,
 Clause 6.3
 SS 333: 2012, Clause 6.5
 SS 333: 2012, Clause 6.4

TEST REPORT(S)

TUV SUD PSB Test Report No.: 7191161709-MEC17-LJH
 TUV SUD PSB Assessment Report No.: 7191330147-MEC24-JC
 SETSCO Test Report No.: SK-8500013426/CCH/1
 SETSCO Test Report No.: MM-8500059071/CY

Detailed configuration and installation shall be referenced to the certified report(s) stated above.



Fiona Leong (Ms)
 Program Manager
 SETSCO Services Pte Ltd

Certificate No

FSP-2019-0788

Date of Issue

20/05/2022

Date of Last Revision

22/07/2024

Date of Expiry

22/05/2027

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10

Multiple modules damper assembly in a drywall construction:

Module arrangement	Individual damper size (mm)	Damper overall size (mm)
1 x 1	1500 x 1500	1500 x 1500
2 x 2	1500 x 1500	3000 x 3000
3 x 1	1500 x 1500	4500 x 1500
4 x 1	1500 x 1500	6000 x 1500

Multiple modules damper assembly in a masonry wall:

Module arrangement	Individual damper size (mm)	Damper overall size (mm)
1 x 1	1500 x 1500	1500 x 1500
2 x 2	1500 x 1500	3000 x 3000
3 x 3	1500 x 1500	4500 x 4500



Fiona Leong (Ms)
Program Manager
SETSCO Services Pte Ltd

Certificate No	Date of Issue	Date of Last Revision	Date of Expiry
FSP-2019-0788	20/05/2022	22/07/2024	22/05/2027

Amendments or additions to this appendix other than those authorized by SETSCO render the appendix invalid.